


SUPPLIER SALMON VALLEY SAND & GRAVEL
 SOURCE SALMON VALLEY PIT - SAMPLE #2
 SPECIFICATION CSA-TABLE 10-FA1
 MATERIAL TYPE C33 FINE AGGREGATE

SAMPLED BY CLIENT
 TESTED BY TY
 TEST METHOD WASHED



GRAVEL SIZES	PERCENT PASSING	GRADATION LIMITS
80 mm		
56 mm		
40 mm		
28 mm		
20 mm		
14 mm		
10 mm		100.0-100.0

SAND SIZES AND FINES	PERCENT PASSING	GRADATION LIMITS
5 mm	100.0	95.0-100.0
2.5 mm	99.3	80.0-100.0
1.25 mm	81.7	50.0-90.0
630 µm	41.7	25.0-65.0
315 µm	10.8	10.0-35.0
160 µm	3.0	2.0-10.0
80 µm	1.2	0.0-3.0

FINENESS MODULUS 2.64 SPEC LIMITS 2.30 - 3.10

MOISTURE CONTENT 6.3%

COMMENTS