


AGGREGATE CHART

CSA A23.1-04
Section 5.4.2 Grading, Table 2
Grading Requirements for Coarse Aggregate
Group 1, 20-5 mm



Sieve Size (mm)	Specification	Total % Passing
28	100 - 100	100
20	85 - 100	97
14	50 - 90	68
10	25 - 60	42
5	0 - 10	2
2.5	0 - 5	1
0.080		

Sieve Size (mm)	Specification	Total % Passing

Client: SALMON VALLEY SAND & GRAVEL	
Sample Description: SALMON RIVER ROCK	
Location: _____	
Specification: _____	
Sampled by: _____	DATE: July 4/12
Screen Analysis: _____	DATE: _____
Copies To: _____	